

ADA Ramp Compliance Assessment Form

Ramp Location: _____

Date: _____

Grade: _____

Step 1 - Is it Maintenance or an Alteration?

Maintenance: _____
 Alteration: _____
 Activity: _____

Activity Type	Maintenance	Alteration
Pavement Activities	Crack filling and sealing	Open-graded surface courses
	Surface sealing	Cape seals
	Fog seals	Hot in-place recycling
	Chip seals	Latex overlays / Microsurfacing
	Slurry seals	Thin lift overlays
	Joint seals and repairs	Overlays
	Dow bar retrofit	Mill & fill / mill & overlay
Other Activities	Spot high-friction treatments	Rehabilitation
	Diamond grinding	Major Rehabilitation*
	Patching	Reconstruction*
	Signal operational adjustment	Signal install/replacement
	Sidewalk repair	Pedestrian signal install/replace
	Sign repair	Sidewalk replacement
	Sign replacement	

Step 2 - What is the Corridor?

Scenario 1: _____
 Scenario 2: _____
 Scenario 3: _____
 Scenario 4: _____

Improvements are required (street level crossings are overlaid)

Improvements are **not** required (street level crossings are **not** overlaid)

*Note: Requirements for improvement apply to both marked and unmarked crosswalks.

Road to be Paved: _____
 Cross Street: _____
 Outside of Corridor: _____

Step 3 - What is the Grade for the Ramp?

Grade A: _____
 Grade B: _____
 Grade C: _____
 Grade D: _____
 NA: _____
 Slopes Within Limit: Yes No
 Tapers: _____
 Flat Area: _____
 Cross Slope: _____

Grade	Ramp Width	Detectable Warning Surface	Material Condition
A <small>(rated only if all listed conditions exist)</small>	48" or greater	Truncated Dome	<u>Fair or Better Condition</u> Limited or tight cracking, faulting (<1/4"), isolated spalling
B <small>(maximum rating if any of the listed condition exists)</small>	>36" to <48"	Exposed Aggregate Surface	<u>Poor Condition</u> Moderate cracking, faulting (1/4"-3/4"), moderate spalling
C <small>(maximum rating if any of the listed condition exists)</small>	36" or less	No detectable warning surface	<u>Very Poor Condition</u> Severe cracking, faulting (>3/4"), extensive spalling
D	A curb ramp is needed but does not exist at the location to access an existing sidewalk where it crosses a curb.		
N/A	A curb ramp is NOT needed at the location (typically because either a sidewalk does not exist or there is no curb at this location).		

Table 2 – Summary of Functional Condition Grade Criteria

Domes: Yes No
 Exposed Aggregate: Yes No

Notes: _____

